

LM-79

Test Report


LM79-REVO-XL-4000K-CRI80-30DEG

General Discription


Item number	RX-1N-22-33
Date and time	28-6-2018 15:41:09
CCT (Kelvin)	3852 K
Beam angle	28,9 x 28,3°
Luminous flux	3137 lm
Efficiency	85 lm/watt
Weighted energy	36,9 kWh/1000h
Power factor	0,95
CRI (RA)	82,8
Fidelity index Rf	Rf 82,6
Gammut index Rg	Rg 97,9
Peak	10254 cd



Polar diagram



Cartesian diagram



CLS LED BV
info@cls-led.com
www.cls-led.com

2017 CLS-LED BV. All rights reserved. Information subject to change without notice, CLS-LED BV and all affiliated companies disclaim liability for injury, damage direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document. No part of this document may be reproduced, in any form or by any means, without permission in writing from CLS-LED BV. Other legal information can be found in our General conditions, found on the back of your CLS-LED BV invoice, inside the CLS catalogue or on our website www.cls-led.com/voorwaarden.pdf

LM-79

Test Report

LM79-REVO-XL-4000K-CRI80-30DEG

Beam details	1m	2m	3m	4m	5m
Lux*	10231 lx	2558 lx	1137 lx	639 lx	409 lx

*measured at center of beam

Footcandles*	950,5 fcd	237,6 fcd	105,6 fcd	59,4 fcd	38,0 fcd
Beam width (meter)	0,5 m	1 m	1,5 m	2 m	2,5 m
Beam width (Feet)	1,7 ft	3,3 ft	5 ft	6,7 ft	8,4 ft

Beam intensities																			
1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
10231lx	2558lx	1137lx	639lx	409lx	284lx	209lx	160lx	126lx	102lx	85lx	71lx	61lx	52lx	45lx	40lx	35lx	32lx	28lx	26lx
3,3ft	6,6ft	9,8ft	13,1ft	16,4ft	19,7ft	23ft	26,2ft	29,5ft	32,8ft	36,1ft	39,4ft	42,7ft	45,9ft	49,2ft	52,5ft	55,8ft	59,1ft	62,3ft	65,6ft
950,5fcd	237,6fcd	105,6fcd	59,4fcd	38fcd	26,4fcd	19,4fcd	14,9fcd	11,7fcd	9,5fcd	7,9fcd	6,6fcd	5,6fcd	4,8fcd	4,2fcd	3,7fcd	3,3fcd	2,9fcd	2,6fcd	2,4fcd

Intensities in 0° c-plane																			
0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
10,2K	10,2K	9,8K	9,3K	8,5K	7,5K	6,5K	5,5K	4,6K	3,8K	3,0K	2,3K	1,7K	1,3K	0,9K	0,7K	0,5K	0,3K	0,3K	0,2K
100%	99%	96%	91%	83%	73%	64%	54%	45%	37%	29%	22%	17%	12%	9%	6%	5%	3%	3%	2%

Intensities in 90° c-plane																			
0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
10,2K	10,1K	9,6K	8,9K	8,0K	7,1K	6,1K	5,1K	4,3K	3,4K	2,7K	2,0K	1,5K	1,1K	0,8K	0,6K	0,4K	0,3K	0,2K	0,2K
100%	98%	94%	87%	79%	69%	59%	50%	42%	34%	26%	20%	14%	10%	8%	5%	4%	3%	2%	2%

Intensities in 180° c-plane																			
0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
10,2K	10,0K	9,5K	8,7K	7,8K	6,8K	5,8K	4,8K	3,9K	3,0K	2,3K	1,7K	1,3K	1,0K	0,7K	0,5K	0,4K	0,3K	0,2K	0,2K
100%	98%	93%	85%	76%	66%	57%	47%	38%	30%	23%	17%	13%	9%	7%	5%	4%	3%	2%	2%

Intensities in 270° c-plane																			
0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
10,2K	10,1K	9,7K	9,1K	8,2K	7,3K	6,3K	5,5K	4,6K	3,8K	3,0K	2,4K	1,8K	1,4K	1,0K	0,8K	0,6K	0,4K	0,3K	0,3K
100%	99%	95%	89%	80%	71%	62%	53%	45%	37%	30%	23%	18%	13%	10%	8%	6%	4%	3%	3%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
28,6°	53,6°	72,2°	98,4%	96,2%



CLS LED BV
 info@cls-led.com
 www.cls-led.com




2017 CLS-LED BV. All rights reserved. Information subject to change without notice, CLS-LED BV and all affiliated companies disclaim liability for injury, damage direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document. No part of this document may be reproduced, in any form or by any means, without permission in writing from CLS-LED BV. Other legal information can be found in our General conditions, found on the back of your CLS-LED BV invoice, inside the CLS catalogue or on our website www.cls-led.com/voorwaarden.pdf

LM-79

Test Report

LM79-REVO-XL-4000K-CRI80-30DEG

Color details



CIE 1931

x: 0,388

3852 K


y: 0,384

Spectra

CIE 1931 ZOOM

Δuv : 0,0011


CRI: 82,8 (R1-R8)



CRI values, R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8
80,8	87,2	92,9	83,3	81,2	83,2	86,6	66,9
R9	R10	R11	R12	R13	R14	R15	
13,3	70,4	82,6	68,3	81,9	95,9	74,4	


CQS: 83,0



CQS values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8
81,3	98,2	80,7	79,7	83,4	83,5	84,8	89,3
Q9	Q10	Q11	Q12	Q13	Q14	Q15	
97,3	87,1	84,6	83,6	83,5	72,9	75,8	

TM30: 82,6



TM30 values, 16 binned values out of total of 99 values

C1	C2	C3	C4	C5	C6	C7	C8
79,9	81,5	73,1	81,6	86,2	89,5	89,6	88,0
C9	C10	C11	C12	C13	C14	C15	
88,4	79,7	78,4	80,4	86,0	85,8	79,4	

Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
3852 K	82,8	13,3	82,6	97,9	83,0	0,388	0,384	0,227	0,337	0,0011



CLS LED BV
info@cls-led.com
www.cls-led.com

2017 CLS-LED BV. All rights reserved. Information subject to change without notice, CLS-LED BV and all affiliated companies disclaim liability for injury, damage direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document. No part of this document may be reproduced, in any form or by any means, without permission in writing from CLS-LED BV. Other legal information can be found in our General conditions, found on the back of your CLS-LED BV invoice, inside the CLS catalogue or on our website www.cls-led.com/voorwaarden.pdf

LM-79

Test Report

LM79-REVO-XL-4000K-CRI80-30DEG

TM30 details


Rf 82,6

Fidelity index Rf


Rg 97,9

Gamut index Rg


Hue Bin	R _f	Graphic shifts (%)	
		Chroma	Hue
1	80	-11%	-2%
2	82	-8%	6%
3	73	-4%	13%
4	82	3%	10%
5	86	6%	6%
6	90	6%	-2%
7	90	0%	-6%
8	88	-4%	-5%
9	88	-7%	-1%
10	80	-8%	7%
11	78	-1%	13%
12	80	5%	8%
13	86	7%	-3%
14	86	9%	-7%
15	79	1%	-13%
16	79	-5%	-12%




Hue binH



Color vector graphics




Hue bin



Color distortion graphics



Color Evaluation Sample



CLS LED BV
info@cls-led.com
www.cls-led.com

2017 CLS-LED BV. All rights reserved. Information subject to change without notice, CLS-LED BV and all affiliated companies disclaim liability for injury, damage direct or indirect loss, consequential or economic loss or any other loss occasioned by the use of, inability to use or reliance on the information contained in this document. No part of this document may be reproduced, in any form or by any means, without permission in writing from CLS-LED BV. Other legal information can be found in our General conditions, found on the back of your CLS-LED BV invoice, inside the CLS catalogue or on our website www.cls-led.com/voorwaarden.pdf

Glare Evaluation According to UGR

p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	12,9	13,6	13,2	13,8	14,0	12,0	12,7	12,3	12,9	13,1
	3H	13,3	13,9	13,6	14,1	14,4	12,4	13,0	12,7	13,3	13,5
	4H	13,4	14,0	13,7	14,2	14,5	12,5	13,1	12,8	13,3	13,6
	6H	13,4	13,9	13,7	14,2	14,5	12,5	13,0	12,8	13,3	13,6
	8H	13,4	13,9	13,7	14,2	14,5	12,5	13,0	12,8	13,3	13,6
	12H	13,3	13,8	13,7	14,1	14,5	12,4	12,9	12,8	13,2	13,6
4H	2H	13,0	13,6	13,3	13,9	14,1	12,2	12,8	12,5	13,0	13,3
	3H	13,5	14,0	13,9	14,3	14,6	12,7	13,1	13,0	13,4	13,8
	4H	13,6	14,1	14,0	14,4	14,7	12,8	13,2	13,2	13,5	13,9
	6H	13,7	14,0	14,1	14,4	14,8	12,8	13,2	13,2	13,5	13,9
	8H	13,7	14,0	14,1	14,4	14,8	12,8	13,1	13,2	13,5	13,9
	12H	13,6	13,9	14,1	14,3	14,8	12,8	13,1	13,2	13,5	13,9
8H	4H	13,6	13,9	14,0	14,3	14,7	12,8	13,1	13,2	13,5	13,9
	6H	13,7	13,9	14,1	14,3	14,8	12,8	13,1	13,3	13,5	13,9
	8H	13,7	13,9	14,1	14,3	14,8	12,8	13,0	13,3	13,5	14,0
	12H	13,7	13,8	14,2	14,3	14,8	12,8	13,0	13,3	13,5	14,0
12H	4H	13,6	13,8	14,0	14,3	14,7	12,7	13,0	13,2	13,4	13,8
	6H	13,6	13,8	14,1	14,3	14,8	12,8	13,0	13,3	13,4	13,9
	8H	13,6	13,8	14,1	14,3	14,8	12,8	13,0	13,3	13,4	13,9
Variation of the observer position for the luminaire distance S											
S = 1,0H		+3,0 / -2,1					+2,8 / -1,9				
S = 1,5H		+5,2 / -2,7					+5,1 / -2,4				
S = 2,0H		+7,0 / -3,4					+6,8 / -3,1				
Standard table		BK02					BK02				
Correction summand		-4,1					-5,0				
Corrected glare indices referring to 3137lm total luminous flux											